



STANDARD STRAIGHT BAR

BAR SIZE	* LOCATION CATEGORY		
	A	B	C
#4	2'-3"	1'-7"	1'-3"
#5	2'-9"	2'-0"	1'-7"
#6	3'-4"	2'-5"	1'-11"
#7	3'-11"	Does Not Exist	2'-3"
#8	5'-2"		2'-11"
#9	6'-6"		3'-9"
#10	8'-3"		4'-9"
#11	10'-1"		5'-9"

\* LOCATION CATEGORY:

- A- Bars in horizontal layers in top of pour with 12" or more of concrete below them such as in: footings, pier caps, etc.
- B- All bars not in Category A spaced less than 6" apart.
- C- All bars not in Category A spaced 6" or more apart.

Note:

CASE NO.2 - For bars coated with epoxy not in Case No.1.

1. When development length is not specified on the Plans, the above dimensions shall be used.
2. These development lengths only apply to 4500 P.S.I. lightweight concrete.
3. These development lengths only apply where the General Notes indicate "Reinforcing Steel Design,  $f_y = 60$  ksi."

APPROVAL	
<i>L.S. Friedman</i> DIRECTOR	OFFICE OF STRUCTURES
DATE: 2/2/90	
REVISIONS	
SHA	FHWA
11-23-93	.
1-22-01	.
9-20-05	.
11-26-07	.
FHWA APPROVAL	
DATE:	

STATE OF MARYLAND DEPARTMENT OF TRANSPORTATION STATE HIGHWAY ADMINISTRATION OFFICE OF STRUCTURES	
DEVELOPMENT LENGTH DIMENSIONS FOR GRADE 60 REINFORCING STEEL IN LIGHTWEIGHT (4500 P.S.I.) CONCRETE EPOXY COATED REINFORCING CASE NO.2	
STANDARD NO. M(6.15)-90-215(L)	SHEET <u>3</u> OF <u>3</u>



MISCELLANEOUS